



Village of McBride
Annual Water System Report – 2022
April 2023



McBride Water System Annual Report for 2022

In 2022 the McBride Water System supplied 141,995,520 litres of potable water to approximately twelve hundred (1200) persons. This year's annual water consumption has increased by 12,798,520 litres. This equates to approximately four hundred (400) connections to the water system. The system utilizes a gravity intake that draws water from Dominion Creek. The water is detained in two underground settling tanks equaling sixty cubic meters (60M³) that slows down the velocity of the water allowing the suspended solids time to settle out before it is delivered to the Water Treatment Plant. The water is first treated with Ultraviolet Light and secondly treated with Chlorine to further treat the water for bacteria. Now that the water has traveled through the treatment process at the treatment plant it is stored below ground in an eight hundred cubic meter (800M³) below ground concrete reservoir until it is needed by the village residents. The water leaves the reservoir through a variety of different types and sizes of pipe that eventually connect to the user's building through a curb stop and a service line.

Village staff have been watching for infrastructure grants that would fund the installation of a pre-treatment filtration system at the McBride the Water Treatment Facility. Staff, aided by Radloff Engineering, began collecting filtration system specific water samples in 2022. These scheduled samples were collected from chosen locations and sent to Wellness Water Testing Laboratory for analysis to ensure we had all the appropriate information and data required to submit for a grant application. The Village submitted an application to UBCM and the Government of Canada's Canada Community -Building Fund in 2022 for a new water filtration system. The Village was successful and was awarded 2.6 million dollars for a new filtration system. Testing is still ongoing to get the required data to ensure the system that is chosen and designed will fit all the Village's needs. Our goal is to choose and design a system that will eliminate the need for a boils water restrictions during Spring runoff and summer freshet.

This year's annual water consumption was higher than last year for a couple reasons. The Village experienced several water breaks inside residential properties. Houses that were not properly heated allowed the plumbing to freeze and break. Several of these breaks went unnoticed for weeks. The leaks were detected in the data at the water plant, but staff were unable to locate the issues to correct them. Eventually property owners that were away had returned home and called in the leaks. The record-breaking temperatures during the summer months increased usage. The necessity to water gardens and yards was greater with considerably less than the normal amount of precipitation during the 2022 gardening season.

Water was sampled 80 times in 2022. The water samples were taken from the following locations:

Table 1
Water Sampling Locations

Location 1: McBride Secondary School
Location 2: McBride Hospital
Location 3: McBride Husky/Esso
Location 4: Dominion Creek Pre-treatment
Location 5: McBride Reservoir

Table 2
Water Quality

Month	Number of samples with Escherichia Coli in Treated Water	Number of Samples with Coliforms in Treated Water	Minimum Turbidity of Raw Water (NTU)	Maximum Turbidity of Raw Water (NTU)	Average Turbidity of Raw Water (NTU)
January	0	0	0.150	0.387	0.200
February	0	0	0.179	0.520	0.252
March	0	0	0.171	0.562	0.261
April	0	0	0.214	0.521	0.367
May	0	0	0.150	0.682	0.266
June	0	0	0.342	2.480	1.120
July	0	0	0.298	1.810	0.882
August	0	0	0.155	0.318	0.252
September	0	0	0.156	0.254	0.368
October	0	0	0.130	0.243	0.156
November	0	0	0.124	0.849	0.199
December	0	0	0.139	0.330	0.194

Escherichia coli (commonly abbreviated E. coli) is commonly found in the lower intestine of warm-blooded organisms. Most E. coli strains are harmless, but some serotypes can cause serious food poisoning in humans and are occasionally responsible for product recalls due to food contamination.

Coliform bacteria are commonly used bacteria indicator of sanitary quality of foods and water. Coliforms can be found in the aquatic environment, in soil and on vegetation; they are universally present in large numbers in the feces of warm-blooded animals. While coliforms themselves do not normally cause serious illness, they are easy to culture, and their presence is used to indicate that other pathogenic organism of fecal origin may be present. Fecal pathogens include bacteria, viruses, or protozoa and many multicellular parasites.

Turbidity is the cloudiness or haziness of a fluid caused by individual particles (suspended solids) that are generally invisible to the naked eye, like smoke in air. The measurement of turbidity is a key test of water quality.

From the data shown previously in Table 2 it is obvious the water quality is very good. The water is not a concern for health risk and is rated as low on the Public Health Protection Website that is operated by Northern Health. Northern Health requires a complete water chemistry test to be completed every five (5) years. A full set of water samples was collected and tested July 17, 2020. This data is shown in Table 3(A-C) below. The full lab report is attached. Only one of the results exceeded the Guidelines for The Canadian Drinking Water Quality Regulations. The test for Turbidity exceeded the guidelines for the Canadian Drinking Water Regulations because the sample was collected during our seasonal freshet. These guidelines are also attached to this report.

Table 3A
Water Chemistry Taken July 17, 2020

Analyte (Metals Extractable)		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Aluminum	Extractable	mg/L	0.067	0.001	0.1	Below OG
Antimony	Extractable	mg/L	<0.00002	0.00002	0.006	Below Mac
Arsenic	Extractable	mg/L	0.0002	0.0001	0.010	Below Mac
Barium	Extractable	mg/L	0.0019	0.0001	2.0	Below Mac
Boron	Extractable	mg/L	<0.002	0.002	5	Below Mac
Cadmium	Extractable	mg/L	<0.00001	0.00001	0.005	Below Mac
Chromium	Extractable	mg/L	0.00015	0.00005	0.05	Below Mac
Copper	Extractable	mg/L	0.0006	0.0005	1AO:2Mac	Below AO
Lead	Extractable	mg/L	0.00038	0.00001	0.005	Below Mac
Selenium	Extractable	mg/L	<0.0002	0.0002	0.05	Below Mac
Strontium	Extractable	mg/L	0.032	0.0001	7.0	Below Mac
Uranium	Extractable	mg/L	0.00013	0.00001	0.02	Below Mac
Vanadium	Extractable	mg/L	<0.00005	0.00005		
Zinc	Extractable	mg/L	0.0009	0.0005	5.0	Below AO

Table 3B

Analyte Physical & Aggregate Properties		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Colour	True	Colour Units	9	5		
Turbidity		NTU	4.06	0.1	0.1	Above OG

Table 3C

Analyte Routine Water		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Ph	At 25 C		7.61	0.01	7.0-10.5	Within Range
Electrical Conductivity		U S/cm at 25 C	56	1		
Calcium	Extractable	mg/L	8.0	0.01		
Iron	Extractable	mg/L	0.13	0.004	0.3	Below AO
Magnesium	Extractable	mg/L	1.3	0.02		
Manganese	Extractable	mg/L	0.016	0.001	0.02 AO 0.12 Mac	Below AO
Potassium	Extractable	mg/L	0.18	0.04		
Silicon	Extractable	mg/L	1.1	0.005		
Sodium	Extractable	mg/L	0.3	0.1	200	Below AO
T-Alkalinity	as CaCO3	mg/L	27	5		
Chloride	Dissolved	mg/L	<0.05	0.05	250	Below AO
Fluoride	Dissolved	mg/L	<0.01	0.01	1.5	Below Mac
Nitrate-N	Dissolved	mg/L	<0.01	0.01	10	Below Mac
Nitrite-N	Dissolved	mg/L	<0.01	0.01	1	Below Mc
Sulfate (SO4)	Dissolved	mg/L	2.0	0.1	500	Below AO
Hardness	As CaCO3	mg/L	25	1		
Total Dissolved Solids	Extractable	mg/L	31	1	500	Below AO

NOTE: Lab results containing < means there is a lower amount than the Detection Limit of the equipment.

Village staff are constantly watching for grant funding for capital projects. One of the higher priorities currently is filtration for the water system. In 2022 McBride was once again on a Boil Water Advisory for 43 days due to high turbidity. This is a huge inconvenience for the residents, businesses, and hospital. Staff started water testing in 2022 to insure we had all the required data and information making the Village eligible for upcoming grant funding. The Village was successful with our grant application and was awarded 2.6 million dollars for a new filtration system. Testing is still ongoing to get the required data to ensure the system that is chosen, and its design will fit all the Village's needs. Our goal is to choose and design a system that will eliminate the need for a boil water restriction during Spring runoff and summer freshet.

The flow meter that measures the volume of water entering the water system and sends its data to the SCADA System failed in 2022. Without the SCADA system knowing how much water was entering the system it had to be adjusted manually by the operators. The system had to be placed in manual mode for three months while staff waited for a new meter to arrive. During this time the water operators had to calculate flows, volumes, and dosages to ensure the water was treated correctly. The new meter was installed in June restoring all systems back to normal.

There have been some improvements made to the SCADA System and more upgrades planned for 2023. We have installed a new cyber security system protecting our system from Hackers. The operators were assigned new password protected accounts for added security and completed cyber security training. We have upgraded our security system allowing the system to alert staff immediately when motion is detected on the video surveillance system.

An Emergency Response Plan was updated and it is posted in numerous locations in case of emergency. A daily log of the chlorine residuals shows that the average yearly concentration is 0.39 mg/l (milligrams per litre) through the distribution system. The breakdown of samples taken per month is shown below in Table 4. Chlorine Residual Samples are taken a minimum of 80 times per month at four different locations in the Village. Environmental Operators Certification Program classified the water treatment and distribution a Level 2 facility. This requires the operators to possess Level 2 training and operational skills to be able to operate the water system.

Table 4**Chlorine Residual throughout the Distribution System**

Month	Average	Minimum	Maximum
January	0.32	0.02	0.54
February	0.24	0.02	0.52
March	0.26	0.02	0.57
April	0.34	0.03	0.71
May	0.49	0.18	0.91
June	0.50	0.13	0.91
July	0.57	0.32	1.11
August	0.43	0.08	0.86
September	0.40	0.03	0.81
October	0.39	0.26	0.58
November	0.38	0.20	0.66
December	0.35	0.19	0.57
Yearly	0.39	0.12	0.73

Table 5**Bacteriological Testing 2020 (Coliforms [Coli] and E. Coli) (Raw Water)**

Date	# of locations	System Intake	Reservoir	McBride Hospital	Secondary School	McBride Husky
January	5	0	0/100ml	0/100ml	0/100ml	0/100ml
February	5	Sample Timed Out	0/100ml	0/100ml	0/100ml	0/100ml
March	5	10.8 Coli/100ml	0/100ml	0/100ml	0/100ml	0/100ml
April	5	34.1 Coli/100 ml 1.0 E. coli/100ml	0/100ml	0/100ml	0/100ml	0/100ml
May	5	21.8 Coli/100 ml 0 E. coli/100ml	0/100ml	0/100ml	0/100ml	0/100ml
June	5	20.3 Coli/100ml 3.1 E. coli/100ml	0/100ml	0/100ml	0/100ml	0/100ml
July	5	22.8 Coli/100ml 1.0 E. Coli/100ml	0/100ml	0/100ml	0/100ml	0/100ml
August	5	Sample Timed Out	0/100ml	0/100ml	0/100ml	0/100ml
September	5	96.0 Coli/100ml 1.0 E. coli/100ml	0/100ml	0/100ml	0/100ml	0/100ml
October	5	69.1 Coli/100ml 0 E. Coli/100ml	0/100ml	0/100ml	0/100ml	0/100ml
November	5	10.7 Coli/100ml 0 E. Coli/100ml	0/100ml	0/100ml	0/100ml	0/100ml
December	5	6.3 Coli/100ml 0 E. coli/100ml	0/100ml	0/100ml	0/100ml	0/100ml



This is a photo taken at the peak of the 2020 freshet. The high turbidity levels are easily visible. During these periods water conservation notices were posted to restrict water usage so we do not bring too much turbid water into the system. During the freshet in 2022 when the first conservation notice was posted our daily water usage increased by 120,000 l/day. It was issued due to high turbidity levels not because there was a shortage of water. We hope that seeing this photo will educate residents why conservation notices are issued.



Dominion Creek near the end of seasonal freshet August 2020

For additional information or if you have any questions concerning the water system and treatment, please contact the Village of McBride at (250) 569-2229 or in person at 100 Robson Centre, 855 SW Frontage Rd., McBride, BC.

The water treatment plant for the Community Water System in McBride is in good operating condition. It is constantly being maintained and upgraded to provide better and more reliable service to the community. Please refer to Northern Health Reports for more information on the samples taken in 2022.

Works Cited

1. Wikipedia, "Escherichia coli", 8 May 2014.(Online). Available: http://en.wikipedia.org/wiki/Escherichia_Coli. (Accessed 24 July 2018)
2. Wikipedia, "Coliform Bacteria", 22 July 2018 (Online). Available: http://en.wikipedia.org/wiki/coliform_bacteria. (Accessed 22 July 2018)
3. Wikipedia, "Turbidity", 12 May 2014. (Online). Available: <http://en.wikipedia.org/wiki/Turbidity>. (Accessed 22 July 2018)
4. Northern health, "Public Health Protection", Northern Health, 22 July 2018. (Online): Available <http://healthspace.ca/nha>. (Accessed 22 July, 2018)



210-1811 Victoria St.
 Prince George, BC V2L2L6
 (250)301-7898
www.wellnesswaterlab.com
contact@wellnesswaterlab.com

Report Status:

- Final
- Pending
- None-Conformance

General Information

Laboratory Report

Client Name:
 SLANEY, MATTHEW

Address:
 100 ROBSON CENTRE MC BRIDE B.C. V0J2E0

Report ID: **4557**
 Water Sampler: SLANEY, MATTHEW
 Collection Date/Time: 2020-07-16 10:30
 Receiving Date/Time: 2020-07-16 12:52
 Analysis Start Date/Time: 2020-07-16 14:00
 Analysis End Date/Time: 2020-07-17 14:00
 Reported Date/Time: 2020-07-17 15:00
 Sample Temperature (°C): *14.0

Bacteriology Results:

Project Name, Address and Source	Lab Reference Number	Microorganisms (MPN/100 ML)		Comment
		Total Coliform	E.Coli	
MC BRIDE COMMUNITY WATER SYSTEM MCBRIDE B.C. V0S2E0 RIVER, WATER SYSTEM INTAKE (RAW)	4557	*62.4	*4.2	*ABOVE MAC

Analytical Comments:

Total coliform and E.coli results exceeded maximum standard limit of <1

The information contained in this report is considered confidential and is intended for the addressee whose name is specified above.
 Should you receive this report by error, please notify us by phone and delete this message from your mailbox.



210-1811 Victoria St.
 Prince George, BC V2L2L6
 (250)301-7898
www.wellnesswaterlab.com
contact@wellnesswaterlab.com

Report Status:

- Final
- Pending
- None-Conformance

General Information

Laboratory Report

Client Name:
 SLANEY, MATTHEW

Address:
 100 ROBSON CENTRE MC BRIDE B.C. V0J2E0

Report ID: **4557**
 Water Sampler: SLANEY, MATTHEW
 Collection Date/Time: 2020-07-16 10:30
 Receiving Date/Time: 2020-07-16 12:52
 Analysis Start Date/Time: 2020-07-16 14:00
 Analysis End Date/Time: 2020-07-17 14:00
 Reported Date/Time: 2020-07-17 15:00
 Sample Temperature (°C): *14.0

Sample Details:

Project Name & Address Provided on Chain of Custody Form and/or Sample Label	Site Code	Collection Date/Time	Hold Time (hh:mm)	Chlorination (mg/L)	Comment
MC BRIDE COMMUNITY WATER SYSTEM MCBRIDE B.C. V0S2E0 RIVER, WATER SYSTEM INTAKE (RAW)	NA	2020-07-16 10:30	3:30	NI	

Note To Clients:

- a) Temperature shown in the above is the average of up to three sample temperatures in the same cooler taken at receipt
- b) Sample Holding Time is the elapsed time between collection date/time and analysis start date/time



210-1811 Victoria St.
 Prince George, BC V2L2L6
 (250)301-7898
www.wellnesswaterlab.com
contact@wellnesswaterlab.com

Report Status:
 Final
 Pending
 None-Conformance

General Information

Laboratory Report

Client Name:
 SLANEY, MATTHEW

Address:
 100 ROBSON CENTRE MC BRIDE B.C. V0J2E0

Report ID:	4557
Water Sampler:	SLANEY, MATTHEW
Collection Date/Time:	2020-07-16 10:30
Receiving Date/Time:	2020-07-16 12:52
Analysis Start Date/Time:	2020-07-16 14:00
Analysis End Date/Time:	2020-07-17 14:00
Reported Date/Time:	2020-07-17 15:00
Sample Temperature (°C):	*14.0

Quality Assurance:

- #1 Positive Control, Klebsiella pneumoniae
- #2 Positive Control, Escherichia coli
- #3 Negative Control, Pseudomonas aeruginosa

Methodology:

Analyte: Total coliform & Escherichia coli
 Method: Enzyme Substrate Colilert 24
 Unit: MPN/100ml
 Detection Limit: 1.0 MPN/100ml

Guideline:

Bacteria Growth Limit: None Detected = 0.0 = <1.0 MPN/100ml
 Sample Temperature: 2 to 10 °C
 Maximum Sample Holding Time: 30 hours

References:

British Columbia Drinking Water Protection Act
 Guideline for Canadian Drinking Water Quality
 Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 Enhanced Water Quality Assurance Program (EWQA)

PHO Approval:

[Provincial Health Officer Approved Laboratory List](#)

Acronyms:

BML: Below Minimum Limit	MPN: Most Probable Number (per 100 ml)	PW: Private Well
BT: Bathroom Tap	NA: Not Applicable	SC: See Comment
BW: Bottled Water	NC: Non-Conformance	SPL: Sampling Point Locator
CWS: Community Water System	NCD: No Collection Date	t: Total Chlorine
EC: E. coli (<i>Escherichia coli</i>)	NCT: No Collection Time	TC: Total Coliform
EML: Exceeded Maximum Limit	NI: Not Indicated	<: Below
f: Free Chlorine	NR: No Result	>: Above
IL: Illegible	NSQ: Not Sufficient Quantity	°C: Degree Celcius
KT: Kitchen Tap	NT: Not Tested	*: Indicates Criteria Not Met
MAC: Maximum Acceptable Concentration	OT: Outside Tap	



210-1811 Victoria St.
Prince George, BC V2L2L6
(250)301-7898
www.wellnesswaterlab.com
contact@wellnesswaterlab.com

Report Status:

- Final
- Pending
- None-Conformance

General Information

Laboratory Report

Client Name:
SLANEY, MATTHEW

Address:
100 ROBSON CENTRE MC BRIDE B.C. V0J2E0

Report ID:	4557
Water Sampler:	SLANEY, MATTHEW
Collection Date/Time:	2020-07-16 10:30
Receiving Date/Time:	2020-07-16 12:52
Analysis Start Date/Time:	2020-07-16 14:00
Analysis End Date/Time:	2020-07-17 14:00
Reported Date/Time:	2020-07-17 15:00
Sample Temperature (°C):	*14.0

Signature Page:

The results and Quality Control validations in this report were reviewed and approved by:

Arian Javaherdashti, MLT, CSMLS, Senior Analyst

The test results and additional information provided in this report applies only to the listed samples and is relevant only for the date, time and exact location of collections. Samples are tested as received and Wellness Water Testing Laboratory Inc. assumes no responsibility for the method of collection or samples shipment condition and disclaims any liability for damages arising from interpretation of results. The person and/or company performing the field work is advised to consult British Columbia Drinking Water official regulatory references when evaluating compliance. Please direct your inquiries about this report to us by phone at 250-301-7898.

Report Transmission Cover Page

Bill To: Wellness Water Testing 210, 1811 Victoria Street Prince George, BC, Canada	Project ID: 4557 Project Name: Matthew Slaney Project Location: McBride Community Water System	Lot ID: 1435402 Control Number: Date Received: Jul 17, 2020 Date Reported: Jul 22, 2020 Report Number: 2531768
Attn: Arian Javaherdashti Sampled By: Matthew Slaney Company:	LSD: McBride, BC V05 2E0 P.O.: 1435402 Proj. Acct. code:	

Contact	Company	Address
Arian Javaherdashti	Wellness Water Testing Laboratory Inc.	210, 1811 Victoria Street Prince George, BC null Phone: (250) 301-7898 Fax: Email: contact@wellnesswaterlab.com

Delivery	Format	Deliverables
Email - Multiple Reports By Lot	PDF	COC / Test Report
Email - Multiple Reports By Lot	Standard Crosstab without Tabs	Test Report
Email - Single Report	PDF	COA
Email - Single Report	PDF	COR
Email - Single Report	PDF	Invoice

Notes To Clients:

- Jul 22, 2020 - Sample 1435402-1; 7133976: Analysis was performed on sample 1435402-1 that exceeded the recommended holding time for nitrate and nitrite analysis.

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report

Bill To: Wellness Water Testing 210, 1811 Victoria Street Prince George, BC, Canada	Project ID: 4557 Project Name: Matthew Slaney Project Location: McBride Community Water System McBride, BC V05 2E0	Lot ID: 1435402 Control Number: Date Received: Jul 17, 2020 Date Reported: Jul 22, 2020 Report Number: 2531768
Attn: Arian Javaherdashti Sampled By: Matthew Slaney Company:	LSD: P.O.: 1435402 Proj. Acct. code:	

Reference Number	1435402-1
Sample Date	July 16, 2020
Sample Time	10:30
Sample Location	
Sample Description	4557 / Water System Intake (RAW) / 15.9 °C
Sample Matrix	Drinking Water

Analyte	Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable					
Aluminum	Extractable mg/L	0.067	0.001	0.1	Below OG
Antimony	Extractable mg/L	<0.00002	0.00002	0.006	Below MAC
Arsenic	Extractable mg/L	0.0002	0.0001	0.010	Below MAC
Barium	Extractable mg/L	0.0019	0.0001	2.0	Below MAC
Boron	Extractable mg/L	<0.002	0.002	5	Below MAC
Cadmium	Extractable mg/L	<0.00001	0.00001	0.005	Below MAC
Chromium	Extractable mg/L	0.00015	0.00005	0.05	Below MAC
Copper	Extractable mg/L	0.0006	0.0005	1 AO; 2 MAC	Below AO
Lead	Extractable mg/L	0.00038	0.00001	0.005	Below MAC
Selenium	Extractable mg/L	<0.0002	0.0002	0.05	Below MAC
Strontium	Extractable mg/L	0.032	0.0001	7.0	Below MAC
Uranium	Extractable mg/L	0.00013	0.00001	0.02	Below MAC
Vanadium	Extractable mg/L	<0.00005	0.00005		
Zinc	Extractable mg/L	0.0009	0.0005	5.0	Below AO
Physical and Aggregate Properties					
Colour	True	Colour units	9	5	
Turbidity		NTU	4.06	0.1	Above OG
Routine Water					
pH - Holding Time			Exceeded		
pH	at 25 °C		7.61	0.01	7.0-10.5 Within Range
Electrical Conductivity		µS/cm at 25 °C	56	1	
Calcium	Extractable mg/L	8.0	0.01		
Iron	Extractable mg/L	0.13	0.004	0.3	Below AO
Magnesium	Extractable mg/L	1.3	0.02		
Manganese	Extractable mg/L	0.016	0.001	0.02 AO; 0.12 MAC	Below AO
Potassium	Extractable mg/L	0.18	0.04		
Silicon	Extractable mg/L	1.1	0.005		
Sodium	Extractable mg/L	0.3	0.1	200	Below AO
T-Alkalinity	as CaCO3 mg/L	27	5		
Chloride	Dissolved mg/L	<0.05	0.05	250	Below AO
Fluoride	Dissolved mg/L	<0.01	0.01	1.5	Below MAC
Nitrate - N	Dissolved mg/L	<0.01	0.01	10	Below MAC
Nitrite - N	Dissolved mg/L	<0.01	0.01	1	Below MAC
Sulfate (SO4)	Dissolved mg/L	2.0	0.1	500	Below AO
Hardness	as CaCO3 (extractable) mg/L	25	1		
Total Dissolved Solids	Extractable mg/L	31	1	500	Below AO

Analytical Report

Bill To: Wellness Water Testing 210, 1811 Victoria Street Prince George, BC, Canada	Project ID: 4557	Lot ID: 1435402
Attn: Arian Javaherdashti	Project Name: Matthew Slaney	Control Number:
Sampled By: Matthew Slaney	Project Location: McBride Community Water System	Date Received: Jul 17, 2020
Company:	LSD: McBride, BC V05 2E0	Date Reported: Jul 22, 2020
	P.O.: 1435402	Report Number: 2531768
	Proj. Acct. code:	

Approved by:

Max Hewitt
Operations Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: Wellness Water Testing 210, 1811 Victoria Street Prince George, BC, Canada	Project ID: 4557 Project Name: Matthew Slaney Project Location: McBride Community Water System LSD: McBride, BC V05 2E0 P.O.: 1435402 Proj. Acct. code:	Lot ID: 1435402 Control Number: Date Received: Jul 17, 2020 Date Reported: Jul 22, 2020 Report Number: 2531768
Attn: Arian Javaherdashti Sampled By: Matthew Slaney Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Alk, pH, EC, Turb in water (BC)	APHA	* Alkalinity - Titration Method, 2320 B	Jul 20, 2020	Element Vancouver
Alk, pH, EC, Turb in water (BC)	APHA	* Conductivity, 2510 B	Jul 20, 2020	Element Vancouver
Alk, pH, EC, Turb in water (BC)	APHA	* pH - Electrometric Method, 4500-H+ B	Jul 20, 2020	Element Vancouver
Anions by IEC in water (VAN)	APHA	* Ion Chromatography with Chemical Suppression of Eluent Cond., 4110 B	Jul 21, 2020	Element Vancouver
Metals SemiTrace (Extractable) in water (VAN)	US EPA	* Metals & Trace Elements by ICP-AES, 6010C	Jul 20, 2020	Element Vancouver
Trace Metals (extractable) in Water (VAN)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8	Jul 20, 2020	Element Vancouver
True Color in water (VAN)	APHA	* Spectrophotometric - Single Wavelength Method, 2120 C	Jul 21, 2020	Element Vancouver
Turbidity - Water (VAN)	APHA	* Turbidity - Nephelometric Method, 2130 B	Jul 18, 2020	Element Vancouver

* Reference Method Modified

References

APHA	Standard Methods for the Examination of Water and Wastewater
US EPA	US Environmental Protection Agency Test Methods

Guidelines

Guideline Description	Health Canada GCDWQ
Guideline Source	Guidelines for Canadian Drinking Water Quality, Health Canada, June 2019
Guideline Comments	MAC = Maximum Acceptable Concentration AO = Aesthetic Objective OG = Operational Guideline for Water Treatment Plants (does not apply to private groundwater wells). Refer to Health Canada for complete guidelines at www.hc-sc.gc.ca

Comments:

- Jul 22, 2020 - Sample 1435402-1; 7133976: Analysis was performed on sample 1435402-1 that exceeded the recommended holding time for nitrate and nitrite analysis.

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Guidelines for Canadian Drinking Water Quality

Summary Tables

June 2022

This document may be cited as follows:

Health Canada (2021). Guidelines for Canadian Drinking Water Quality—Summary Tables. Water and Air Quality Bureau, Healthy Environments and Consumer Safety Branch, Health Canada, Ottawa, Ontario.

The document was prepared by Health Canada in collaboration with the Federal-Provincial-Territorial Committee on Drinking Water of the Federal-Provincial-Territorial Committee on Health and the Environment.

Any questions or comments on this document may be directed to the following

Water and Air Quality Bureau
Healthy Environments and Consumer Safety Branch
Health Canada
Tel.: 1-833-223-1014 (toll free)
Fax: 613-952-2574
E-mail: hc.water-eau.sc@canada.ca

Other documents for the Guidelines for Canadian Drinking Water Quality can be found on the following web page:
<https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality.html>

Table of Contents

Introduction.....	1
Abbreviations.....	2
Tables.....	3
Table 1. Microbiological Parameters.....	3
Table 2. Chemical and Physical Parameters.....	7
Table 3. Radiological Parameters.....	32
Table 4. Guidance Documents.....	34
Table 5. Withdrawn Guidelines.....	36
Table 6. Guidelines and Guidance in Progress.....	38



Introduction

The Guidelines for Canadian Drinking Water Quality are established by Health Canada in collaboration with the [Federal-Provincial-Territorial Committee on Drinking Water](#) (CDW) and other federal government departments. Health Canada publishes the guidelines and other information on the website [Drinking water quality in Canada](#). The tables in this document summarize the values and key information from each of the guidelines. **Health Canada updates this document regularly, but you should always consult individual guideline technical documents and guidance documents on the website [Water Quality—Reports and Publications](#) for the most current information.**

Each guideline was established based on current, published scientific research related to health effects, aesthetic effects, and operational considerations. Guidelines (maximum acceptable concentrations or treatment goals) are based on a comprehensive review of the known health effects associated with each contaminant, on exposure levels and on the availability of treatment and analytical technologies. Aesthetic objectives (e.g., for taste or odour) are provided when they play a role in determining whether consumers will consider the water drinkable. Operational guidance values are provided when a substance may interfere with or impair a treatment process or technology (e.g., turbidity interfering with chlorination or UV disinfection) or adversely affect drinking water infrastructure (e.g., corrosion of pipes).

Guidelines for Canadian Drinking Water Quality are established specifically for contaminants that meet all of the following criteria:

1. Exposure to the contaminant could lead to adverse health effects in humans;
2. The contaminant is frequently detected or could be expected to be found in a large number of drinking water supplies throughout Canada; and
3. The contaminant is detected, or could be expected to be detected, in drinking water at a level that is of possible human health significance.

If a contaminant or issue of interest does not meet all these criteria, Health Canada and CDW may choose not to establish a numerical guideline or develop a guideline technical document. In that case, advice may be provided through a guidance document in order to convey operational or management information related to a contaminant or issue of concern.

Guidelines are [systematically reviewed](#) to assess the need to update them. When a guideline is reaffirmed, both the year of the original publication and the year of reaffirmation are shown below after the name of the parameter.

Abbreviations

A	acceptability (parameter type)
ALARA	as low as reasonably achievable
AO	aesthetic objective
CDW	Federal-Provincial-Territorial Committee on Drinking Water
D	disinfectant (parameter type)
DBP	disinfectant by-product (parameter type)
HPC	heterotrophic plate count
I	inorganic chemical (parameter type)
MAC	maximum acceptable concentration
NTU	nephelometric turbidity units
O	organic chemical (parameter type)
OG	operational guidance value
P	pesticide (parameter type)
QMRA	quantitative microbial risk assessment
T	treatment-related (parameter type)
TCU	true colour units

Tables

Table 1. Microbiological Parameters

In general, the highest priority guidelines are those dealing with microbiological contaminants, such as bacteria, protozoa and viruses. Since it is difficult to perform routine analysis of harmful microorganisms that might be present in inadequately treated drinking water, the microbiological guidelines focus on indicator organisms, such as E.coli and total coliforms, and treatment goals for pathogens. The use of a source-to-tap approach that includes source water protection, adequate treatment, and a well-maintained distribution system helps to reduce microorganisms to levels that have not been associated with illness and meet the guidelines outlined below.

Parameter (published, reaffirmed)	Guideline	Common Sources	Health Considerations	Applying the Guideline and Comments
Enteric protozoa: <i>Giardia</i> and <i>Cryptosporidium</i> (2019)	Treatment goal: Minimum 3 log removal and/or inactivation of cysts and oocysts	Human and animal feces	<i>Giardia</i> and <i>Cryptosporidium</i> are commonly associated with gastrointestinal upset (nausea, vomiting, and diarrhoea). Less common health effects vary. <i>Giardia</i> infections may include prolonged gastrointestinal upset, malaise and malabsorption. <i>Cryptosporidium</i> infections, in immunocompromised individuals, can occur outside the gastrointestinal tract.	Monitoring for <i>Cryptosporidium</i> and <i>Giardia</i> in source waters will provide valuable information for a risk-based assessment of treatment requirements. Depending on the source water quality, a greater log removal and/or inactivation may be required.
Enteric viruses (2019)	Treatment goal: Minimum 4 log reduction (removal and/or inactivation) of enteric viruses	Human feces	Commonly associated with gastrointestinal upset (nausea, vomiting, diarrhoea); less common health effects can include respiratory symptoms, central nervous system infections, liver	Enteric viruses have been detected in surface and groundwater sources. Routine monitoring for viruses is not practical, and assessing the vulnerability of source waters to

Parameter (published, reaffirmed)	Guideline	Common Sources	Health Considerations	Applying the Guideline and Comments
			infections and muscular syndromes.	viral contamination is difficult; thus, treatment is a way to reduce risk. Disinfection is a critical barrier.
<i>Escherichia coli</i> (<i>E. coli</i>) (2020)	MAC: None detectable per 100 mL	Human and animal feces	<i>E. coli</i> is an indicator of fecal contamination that is used as a tool to verify the quality of the drinking water. Its detection indicates recent fecal contamination and that microorganisms capable of causing gastrointestinal illnesses may also be present. Pathogens in human and animal feces pose the greatest immediate danger to public health.	In <u>water leaving a treatment plant</u> , the presence of <i>E. coli</i> indicates a serious breach in treatment. In a <u>distribution or storage system</u> , detection of <i>E. coli</i> can indicate that the water has become contaminated during distribution. In <u>non-disinfected groundwater</u> , the presence of <i>E. coli</i> indicates that the groundwater has been affected by fecal contamination. <i>E. coli</i> should be monitored in conjunction with other indicators, as part of a source-to-tap approach to producing drinking water of an acceptable quality.
Total coliforms (2020)	MAC of none detectable/100 mL in water leaving a treatment plant and in non-disinfected groundwater leaving the well	Human and animal feces; naturally occurring in water, soil and vegetation	Total coliforms are not used as indicators of potential health effects from pathogenic microorganisms; they are used as a tool to determine how well the drinking water treatment system is operating and to indicate water quality changes in the distribution system.	Total coliforms should be monitored in the distribution system because they are used to indicate changes in water quality. In <u>water leaving a treatment plant</u> , total coliforms should be measured in conjunction with other indicators to assess water quality; the presence of total coliforms

Parameter (published, reaffirmed)	Guideline	Common Sources	Health Considerations	Applying the Guideline and Comments
				<p>indicates a serious breach in treatment.</p> <p>In a <u>distribution and storage system</u>, detection of total coliforms can indicate regrowth of the bacteria in biofilms or intrusion of untreated water.</p> <p>Detection of total coliforms from consecutive samples from the same site or from more than 10% of the samples collected in a given sampling period should be investigated.</p> <p>In <u>non-disinfected groundwater</u>, the presence of total coliforms may indicate that the system is vulnerable to contamination, or it may be a sign of bacterial regrowth.</p>
Turbidity (2012)	Treatment limits for individual filters or units: - Conventional and direct filtration: $\leq 0.3 \text{ NTU}^1$ - slow sand and diatomaceous	Naturally occurring particles: <i>Inorganic</i> : clays, silts, metal precipitates <i>Organic</i> : decomposed plant & animal debris, microorganisms	Particles can harbour microorganisms, protecting them from disinfection, and can entrap heavy metals and biocides; elevated or fluctuating turbidity in filtered water can indicate a problem with the water treatment process and a potential increased risk of pathogens in treated water.	Guidelines apply to individual filter turbidity for systems using surface water or groundwater under the direct influence of surface water. The decision to exempt a waterworks from filtration should be made by the appropriate authority based on site-specific considerations, including historical

Parameter (published, reaffirmed)	Guideline	Common Sources	Health Considerations	Applying the Guideline and Comments
	earth filtration: ≤ 1.0 NTU ² - membrane filtration: ≤ 0.1 NTU ³			and ongoing monitoring data. To ensure effectiveness of disinfection and for good operation of the distribution system, it is recommended that water entering the distribution system have turbidity levels of 1.0 NTU or less. For systems that use groundwater, turbidity should generally be below 1.0 NTU. Filtration systems should be designed and operated to reduce turbidity levels as low as reasonably achievable and strive to achieve a treated water turbidity target from individual filters of less than 0.1 NTU.

¹ in at least 95% of measurements either per filter cycle or per month; never to exceed 1.0 NTU.

² in at least 95% of measurements either per filter cycle or per month; never to exceed 3.0 NTU.

³ in at least 99% of measurements per operational filter period or per month. Measurements greater than 0.1 NTU for a period greater than 15 minutes from an individual membrane unit should immediately trigger an investigation of the membrane unit integrity.

Table 2. Chemical and Physical Parameters

Guidelines for chemical and physical parameters are the following:

1. health based and listed as maximum acceptable concentrations (MAC);
2. based on aesthetic considerations and listed as aesthetic objectives (AO); or
3. established based on operational considerations and listed as operational guidance values (OG).

In general, the highest priority guidelines are those dealing with microbiological contaminants. Any measure taken to reduce concentrations of chemical contaminants should not compromise the effectiveness of disinfection.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
T	Aluminum (2021)	2.9	OG: 0.1	Naturally occurring; aluminum salts used as coagulants in drinking water treatment; leaching from cement-based materials; dissolution of activated alumina media (where applicable)	Health basis of MAC: Neuromuscular effects (hind- and fore-limb grip strength, foot splay), urinary tract effects and general toxicity.	The MAC and OG apply to all drinking water supplies (including groundwater) and are to be applied as locational running annual averages. The OG value is established to minimize the potential for the accumulation and release of metals in the distribution system and to avoid other operational and aesthetic issues. It takes treatment achievability into consideration.
I	Ammonia (2013)	None required		Naturally occurring; released from agricultural	Levels of ammonia, either naturally present in the	To help prevent nitrification, limit excess

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
				or industrial wastes; added as part of chloramination for drinking water disinfection	source water or added as part of a disinfection strategy, can affect water quality in the distribution system (e.g., nitrification) and should be monitored. A guideline value is not necessary as it is produced in the body and efficiently metabolized in healthy people; no adverse effects at levels found in drinking water.	free ammonia entering the distribution system to below 0.1 mg/L, and preferably below 0.05 mg/L, measured as nitrogen. Nitrification can lead to the formation of nitrite/nitrate, decreased chloramine residual and increased bacterial count.
I	Antimony (1997)	0.006		Naturally occurring (erosion); soil runoff; industrial effluents; leaching from plumbing materials and solder	Health basis of MAC: Microscopic changes in organs and tissues (thymus, kidney, liver, spleen, thyroid)	MAC takes into consideration analytical achievability; plumbing should be thoroughly flushed before water is used for consumption.
I	Arsenic (2006)	0.010 ALARA		Naturally occurring (erosion and weathering of soils, minerals, ores); releases from mining; industrial effluent	Health basis of MAC: Cancer (lung, bladder, liver, skin) (classified as human carcinogen) Other: Skin, vascular and neurological effects (numbness and tingling of extremities)	MAC based on treatment achievability; elevated levels associated with certain groundwaters; levels should be kept as low as reasonably achievable.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Asbestos (1989, 2005)	None required		Naturally occurring (erosion of asbestos minerals and ores); decay of asbestos-cement pipes		Guideline value not necessary; no evidence of adverse health effects from exposure through drinking water.
P	Atrazine (1993)	0.005		Leaching and/or runoff from agricultural use	Health basis of MAC: Developmental effects (reduced body weight of offspring) Other: Potential increased risk of ovarian cancer or lymphomas (classified as possible carcinogen)	MAC applies to sum of atrazine and its <i>N</i> -dealkylated metabolites - diethylatrazine, deisopropylatrazine, hydroxyatrazine, diaminochlorotriazine; Persistent in source waters.
I	Barium (2020)	2.0		Naturally occurring; releases or spills from industrial uses	Health basis of MAC: Kidney effects	MAC is for total barium and takes into consideration exposure estimates from all sources.
O	Benzene (2009)	0.005		Releases or spills from industrial uses	Health basis of MAC: Bone marrow (red and white blood cell) changes and cancer (classified as human carcinogen) Other: Blood system and immunological responses	MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
O	Benzo[a]pyrene (2016)	0.000 04		Leaching from liners in water distribution systems	Health basis of MAC: Stomach tumours (classified as human carcinogen)	
I	Boron (1990)	2		Naturally occurring; leaching or runoff from industrial use	Health basis of MAC: Reproductive effects (testicular atrophy, spermatogenesis) Other: Limited evidence of reduced sexual function in men	MAC based on treatment achievability.
DBP	Bromate ³ (2018)	0.01		Contaminant in hypochlorite solution; by-product of drinking water disinfection with ozone	Health basis of MAC: Tumours of the testicular mesothelium (classified as a possible human carcinogen)	Efforts to reduce bromate concentrations must not compromise the effectiveness of disinfection. Bromate is difficult to remove from drinking water once formed. The recommended strategy is controlling the ozonation process; use of certified treatment chemicals and; appropriate handling and storage of hypochlorite. Quarterly monitoring of raw water bromide is recommended to allow

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
						correlation to bromate or brominated DBPs.
P	Bromoxynil (1987, 2005)	0.005		Leaching or runoff from agricultural use	Health basis of MAC: Reduced liver to body weight ratios	
I	Cadmium (2020)	0.007		Leaching from galvanized pipes and solders ; industrial and municipal waste	Health basis of MAC: Kidney damage. Other: Bone effects (decreased bone density)	MAC is for total cadmium and takes into consideration exposure estimates from all sources. Sampling should be done at the tap to reflect average exposure similar to sampling done for lead. The contribution of cadmium in drinking water is generally from the galvanized steel used in pipes and well components. The best approach to minimize exposure to cadmium from drinking water is to replace galvanized steel and components. Drinking water treatment devices are also an effective option.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Calcium (1987, 2005)	None required		Naturally occurring (erosion and weathering of soils, minerals, ores)	No evidence of adverse health effects from calcium in drinking water.	Guideline value not necessary; calcium contributes to hardness.
O	Carbon tetrachloride (2010)	0.002		Industrial effluents and leaching from hazardous waste sites	Health basis of MAC: Liver toxicity Other: Kidney damage; liver tumours (classified as probable carcinogen)	MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing.
D	Chloramines (2020)	None required		Monochloramine is used as a secondary disinfectant; formed in drinking water when chlorine is added in the presence of ammonia	Guideline value not necessary due to low toxicity at concentrations found in drinking water	Chloramine residuals in most Canadian drinking water distribution systems are typically below 4 mg/L.
DBP	Chlorate (2008)	1		By-product of drinking water disinfection with chlorine dioxide; possible contaminant in hypochlorite solution	Health basis of MAC: Thyroid gland effects (colloid depletion)	As chlorate is difficult to remove once formed, its formation should be controlled by respecting the maximum feed dose of 1.2 mg/L of chlorine dioxide and managing /monitoring formation in hypochlorite solutions.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Chloride (1979, 2005)		AO: ≤ 250	Naturally occurring (seawater intrusion); dissolved salt deposits, highway salt, industrial effluents, oil well operations, sewage, irrigation drainage, refuse leachates	A guideline value is not necessary as health effects are not of concern at levels found in drinking water.	Based on taste and potential for corrosion in the distribution system.
D	Chlorine (2009)	None required		Used as drinking water disinfectant	A guideline value is not necessary due to low toxicity at concentrations found in drinking water	Free chlorine concentrations in most Canadian drinking water distribution systems range from 0.04 to 2.0 mg/L.
D	Chlorine dioxide (2008)	None required		Used as drinking water disinfectant (primary disinfection only)	A guideline value for chlorine dioxide is not required because of its rapid reduction to chlorite in drinking water	A maximum feed dose of 1.2 mg/L of chlorine dioxide should not be exceeded to control the formation of chlorite and chlorate.
DBP	Chlorite (2008)	1		By-product of drinking water disinfection with chlorine dioxide	Health basis of MAC: Neurobehavioural effects (lowered auditory startle amplitude, decreased exploratory activity), decreased absolute brain weight, altered liver weights	Chlorite formation should be controlled by respecting the maximum feed dose of 1.2 mg/L of chlorine dioxide and managing /monitoring formation in hypochlorite solutions.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
P	Chlorpyrifos (1986)	0.09	None	Leaching and/or runoff from agricultural or other uses	Health basis of MAC: Nervous system effects (cholinesterase inhibition)	Not expected to leach significantly into groundwater.
I	Chromium (2018)	0.05		Naturally occurring (erosion of minerals); releases or spills from industrial uses	Health basis of MAC: Hyperplasia of the small intestine from chromium (VI). Other: No definitive evidence of toxicity to Chromium (III).	MAC protects against both cancer and non-cancer effects from Chromium (VI) and is established for total chromium.
T	Colour (1979, 2005)		AO: ≤ 15 TCU	Naturally occurring organic substances, metals; industrial wastes	A guideline value is not necessary as health effects are not of concern at levels found in drinking water.	May interfere with disinfection; removal is important to ensure effective treatment.
I	Copper (2019)	2	AO: 1	Naturally occurring; leaching from copper piping	Health basis of MAC: Gastrointestinal effects (short-term), liver and kidney effects (long-term).	Water samples should be taken at the tap. MAC is for total copper and protects against both short term and long term exposures. AO is based on taste and water discolouration (resulting in staining of laundry and plumbing fixtures).

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Cyanide (1991)	0.2		Industrial and mining effluents; release from organic compounds	Health basis of MAC: No clinical or other changes at the highest dose tested	At the levels seen in Canadian waters, cyanide is not a concern as it can be detoxified to a certain extent in the human body.
O	Cyanobacterial toxins (2018)	0.0015		Naturally occurring - released from populations of cyanobacteria (planktonic blooms and benthic mats)	Health basis of MAC: Liver effects	MAC is for total microcystins (intra- and extra-cellular) Note that infants can ingest a significantly larger volume of water per body weight. As a precautionary measure, where levels of total microcystins in treated water are detected above a reference value of 0.4 µg/L, the public in the affected area should use an alternate suitable source of drinking water (such as bottled water) to reconstitute infant formula.
P	Dicamba (2021)	0.11		Leaching or runoff from agricultural or other uses	Health basis of MAC: Liver effects	Readily leaches into groundwater.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
O	1,4-Dichlorobenzene ² (1987)	0.005	AO: ≤ 0.001	Releases or spills from industrial effluents; use of urinal deodorants	Health basis of MAC: Benign liver tumours and adrenal gland tumours (classified as probable carcinogen)	AO based on odour; levels above the AO would render drinking water unpalatable.
O	1,2-Dichloroethane (2014)	0.005		Releases or spills from industrial effluents; leachate from waste disposal	Health basis of MAC: Cancer of the mammary gland (classified as probable carcinogen)	The MAC protects against both cancer and non-cancer effects and takes into consideration all exposures from drinking water, which include ingestion as well as inhalation and dermal absorption during showering and bathing.
O	1,1-Dichloroethylene (1994)	0.014		Releases or spills from industrial effluents	Health basis of MAC: Liver effects (fatty changes)	
O	Dichloromethane (2011)	0.05		Industrial and municipal wastewater discharges	Health basis of MAC: Liver effects (liver foci and areas of cellular alteration). Other: Classified as probable carcinogen	The MAC protects against both cancer and non-cancer effects and takes into consideration all exposures from drinking water, which include ingestion as well as inhalation and dermal absorption during showering and bathing.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
P	2,4-Dichlorophenoxy acetic acid (2,4-D) (1991)	0.1		Leaching and/or runoff from use as a weed controller; releases from industrial effluents	Health basis of MAC: Kidney effects (tubular cell pigmentation)	MAC takes into consideration exposure estimates from all sources.
P	Dimethoate (1986, 2005)	0.02		Leaching and/or runoff from residential, agricultural and forestry use	Health basis of MAC: Nervous system effects (cholinesterase inhibition)	MAC takes into consideration exposure estimates from all sources.
I	1,4-Dioxane (2021)	0.050		Generally not detected in Canadian water supplies, but there have been contaminations of drinking water supplies near landfills and industrial sites	Health basis of MAC: liver effects that occur before the development of cancer	1,4 Dioxane is difficult to remove using conventional drinking water treatment. Treatment technologies such as advanced oxidation processes and synthetic adsorbents need to be considered. Reverse osmosis membranes may be capable of removing 1,4-dioxane at both the municipal and residential scale.
P	Diquat (2021)	0.05		Leaching and/or runoff from agricultural use; added directly to water to control aquatic weeds	Health basis of MAC: Cataract formation	Unlikely to leach into groundwater.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
O	Ethylbenzene (2014)	0.14	AO: 0.0016	Emissions, effluents or spills from petroleum and chemical industries	Health basis of MAC: Effects on the liver and pituitary gland. Other: Tumour formation at various sites in animals, including kidney, lung, liver and testes.	MAC protects against both cancer and non-cancer health effects. MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing. AO is based on odour.
I	Fluoride (2010)	1.5		Naturally occurring (rock and soil erosion); may be added to promote dental health	Basis of MAC: Moderate dental fluorosis (based on cosmetic effect, not health)	Beneficial in preventing dental caries.
DBP	Formaldehyde (1997)	None required		By-product of disinfection with ozone; releases from industrial effluents	A guideline value is not necessary as health effects are not of concern at levels found in drinking water.	A guideline value is not necessary, as levels in drinking water are below the level at which adverse health effects may occur.
P	Glyphosate (1987, 2005)	0.28		Leaching and/or runoff from various uses in weed control	Health basis of MAC: Reduced body weight gain	Not expected to migrate to groundwater.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
DBP	Haloacetic acids – Total (HAAs) ³ (2008)	0.08 ALARA		By-product of drinking water disinfection with chlorine	Health basis of MAC: Liver cancer (DCA); DCA is classified as probably carcinogenic to humans Other: Other organ cancers (DCA, DBA, TCA); liver and other organ effects (kidney and testes weights) (MCA)	Refers to the total of monochloroacetic acid (MCA), dichloroacetic acid (DCA), trichloroacetic acid (TCA), monobromoacetic acid (MBA) and dibromoacetic acid (DBA); MAC is based on ability to achieve HAA levels in distribution systems without compromising disinfection; precursor removal limits formation.
T	Hardness (1979)	None required		Naturally occurring (sedimentary rock erosion and seepage, runoff from soils); levels generally higher in groundwater	Although hardness may have significant aesthetic effects, a guideline has not been established because public acceptance of hardness may vary considerably according to the local conditions; major contributors to hardness (calcium and magnesium) are not of direct public health concern	Hardness levels between 80 and 100 mg/L (as CaCO ₃) provide acceptable balance between corrosion and incrustation; where a water softener is used, a separate unsoftened supply for cooking and drinking purposes is recommended.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Iron (1978, 2005)		AO: ≤ 0.3	Naturally occurring (erosion and weathering of rocks and minerals); acidic mine water drainage, landfill leachates, sewage effluents and iron-related industries	No evidence exists of dietary iron toxicity in the general population.	Based on taste and staining of laundry and plumbing fixtures.
I	Lead (2019)	0.005 ALARA		Leaching from plumbing (lead service lines, lead solder and brass fittings)	<p>Health basis of MAC: Reduced intelligence in children measured as decreases in IQ is the most sensitive and well established health effect of lead exposure. There is no known safe exposure level to lead.</p> <p>Other: Possible effects include behavioral effects in children. Reduced cognition, increased blood pressure, and renal dysfunction in adults are also possible; classified as probably carcinogenic to humans</p>	MAC is for total lead. Lead levels should be kept as low as reasonably achievable. Sampling should be done at the tap to reflect average exposure. The most significant contribution of lead in drinking water is generally from the lead service line that supplies drinking water to the home. The best approach to minimize exposure to lead from drinking water is to remove the full lead service line. Drinking water treatment devices are also an effective option.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Magnesium (1978)	None required		Naturally occurring (erosion and weathering of rocks and minerals)	No evidence of adverse health effects from magnesium in drinking water, therefore a guideline value is not necessary.	No additional comments.
P	Malathion (1986, 2005)	0.19		Leaching and/or runoff from agricultural and other uses	Health basis of MAC: Nervous system effects (cholinesterase inhibition)	Not expected to leach into groundwater.
I	Manganese (2019)	0.12	AO: ≤ 0.02	Dissolution of naturally occurring minerals commonly found in soil and rock. Other sources include industrial discharge, mining activities and leaching from landfills.	Health Basis of MAC: Effects on neurological development and behaviour; deficits in memory, attention, and motor skills. Other: Formula-fed infants (where water containing manganese at levels above the MAC is used to prepare formula) may be especially at risk.	AO based on minimizing the occurrence of discoloured water, consumer complaints and staining of laundry.
I	Mercury (1986)	0.001		Releases or spills from industrial effluents; waste disposal; irrigation or drainage of areas where agricultural pesticides are used	Health basis of MAC: Irreversible neurological symptoms	Applies to all forms of mercury; mercury generally not found in drinking water, as it binds to sediments and soil.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
P	2-Methyl-4-chlorophenoxyacetic acid (MCPA) (2010)	0.1		Leaching and/or runoff from agricultural and other uses	Health basis of MAC: Kidney effects (increased absolute and relative weights, urinary bilirubin, crystals and pH) Other: Systemic, liver, testicular, reproductive/developmental and nervous system effects	Can potentially leach into groundwater.
O	Methyl tertiary-butyl ether (MTBE) (2006)		AO: ≤ 0.015	Spills from gasoline refineries, filling stations and gasoline-powered boats; seepage into groundwater from leaking storage tanks	The AO is lower than levels associated with potential toxicological effects, it is considered protective of human health. Studies on toxic effects remain inconclusive.	AO based on odour; levels above the AO would render water unpalatable.
P	Metribuzin (2021)	0.08		Leaching and/or runoff from agricultural use	Health basis of MAC: Liver effects (increased ornithine carboxytransferase, increased incidence and severity of mucopolysaccharide droplets, hepatic necrobiosis)	Leaching into groundwater depends on topography, precipitation and site-specific soil characteristic such as organic matter content and soil pH.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Nitrate (2013)	45 as nitrate; 10 as nitrate-nitrogen		Naturally occurring; leaching or runoff from agricultural fertilizer use, manure and domestic sewage; may be produced from excess ammonia or nitrification in the distribution system	Health basis of MAC: Methaemoglobinaemia (blue baby syndrome) and effects on thyroid gland function in bottle-fed infants Other: Classified as possible carcinogen under conditions that result in endogenous nitrosation	Systems using chloramine disinfection or that have naturally occurring ammonia should monitor the level of nitrate in the distribution system. Homeowners with a well should test concentration of nitrate in their water supply.
I	Nitritotriacetic acid (NTA) (1990)	0.4		Sewage contamination	Health basis of MAC: Kidney effects (nephritis and nephrosis) Other: Classified as possible carcinogen	MAC is based upon exposure mainly attributable (80%) to drinking water with 20% of exposure attributable to food.
I	Nitrite (2013)	3 as nitrite; 1 as nitrite-nitrogen		Naturally occurring; leaching or runoff from agricultural fertilizer use, manure and domestic sewage; may be produced from excess ammonia or nitrification in the distribution system	Health basis of MAC: Methaemoglobinaemia (blue baby syndrome) in bottle-fed infants less than 6 months of age Other: Classified as possible carcinogen under conditions that result in endogenous nitrosation	Systems using chloramine disinfection or that have naturally occurring ammonia should monitor the level of nitrite in the distribution system. Homeowners with a well should test concentration of nitrite in their water supply.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
DBP	N-Nitroso dimethylamine (NDMA) (2010)	0.000 04		By-product of drinking water disinfection with chlorine or chloramines; industrial and sewage treatment plant effluents	Health basis of MAC: Liver cancer (classified as probable carcinogen)	MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing.; levels should be kept low by preventing formation during treatment.
A	Odour (1979, 2005)		Inoffensive	Biological or industrial sources	Not applicable	Important to provide drinking water with no offensive odour, as consumers may seek alternative sources that are less safe.
O	Pentachlorophenol (1987, 2005)	0.06	AO: ≤ 0.03	By-product of drinking water disinfection with chlorine; industrial effluents	Health basis of MAC: Reduced body weight, changes in clinical parameters, histological changes in kidney and liver, reproductive effects (decreased neonatal survival and growth)	AO based on odour; levels above the AO would render drinking water unpalatable.
O	Perfluorooctane Sulfonate (PFOS) (2018)	0.0006		Synthetic chemical used in consumer products and fire-fighting foams for their	Health basis of MAC: Adverse effects in the liver. Additional effects at	Additive effects with PFOA were considered. The sum of PFOS and

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
				water and oil repellant properties.	low doses include thyroid and immune effects and changes in serum lipid levels.	PFOA concentrations in drinking water divided by their respective MAC should not exceed 1.
O	Perfluorooctanoic Acid (PFOA) (2018)	0.0002		Synthetic chemical used in consumer products and fire-fighting foams for their water and oil repellant properties.	Health basis of MAC: Adverse effects in the liver. Additional effects at low doses include delay in mammary, estrogenic and developmental effects.	Additive effects with PFOS were considered. The sum of PFOA and PFOS concentrations in drinking water divided by their respective MAC should not exceed 1.
T	pH (2015)		7.0–10.5 ⁴	Not applicable	Not applicable	The control of pH is important to maximize treatment effectiveness, control corrosion and reduce leaching from distribution system and plumbing components.
I	Selenium (2014)	0.05		Naturally occurring (erosion and weathering of rocks and soils) and release from coal ash from coal-fired power plants and mining, refining of copper and other metals.	Health basis of MAC: chronic selenosis symptoms in humans following exposure to high levels Other: Hair loss, tooth decay, weakened nails and nervous system disturbances at extremely high levels of exposure	Selenium is an essential nutrient. Most exposure is from food; little information on toxicity of selenium from drinking water. Selenium can be found in non-leaded brass alloy where it is added to replace lead.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
I	Silver (1986, 2005)	None required		Naturally occurring (erosion and weathering of rocks and soils)	Not applicable	Guideline value not required as drinking water contributes negligibly to an individual's daily intake.
I	Sodium (1979)		AO: ≤ 200	Naturally occurring (erosion and weathering of salt deposits and contact with igneous rock, seawater intrusion); sewage and industrial effluents; sodium-based water softeners	For persons on strict sodium-reduced diets applying to all sources, levels in drinking water should be below 20 mg/L	Based on taste; where a sodium-based water softener is used, a separate unsoftened supply for cooking and drinking purposes is recommended.
I	Strontium (2019)	7.0		Naturally occurring (erosion and weathering of rocks); effluents from mining or other industries	Health basis of MAC: Bone effects (adverse effects on bone formation in infants as well as rickets, osteomalacia)	MAC is protective of the most sensitive sub-population, infants.
I	Sulphate (1994)		AO: ≤ 500	Industrial wastes	High levels (above 500 mg/L) can cause physiological effects such as diarrhoea or dehydration	Based on taste; it is recommended that health authorities be notified of drinking water sources containing sulphate concentrations above 500 mg/L.
I	Sulphide (1992)		AO: ≤ 0.05	Can occur in the distribution system from	Not applicable	Based on taste and odour; levels above the

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
				the reduction of sulphates by sulphate-reducing bacteria; industrial wastes		AO would render water unpalatable.
A	Taste (1979, 2005)		Inoffensive	Biological or industrial sources	Not applicable	Important to provide drinking water with no offensive taste, as consumers may seek alternative sources that are less safe.
T	Temperature (1979, 2005)		AO: ≤ 15°C	Not applicable	Not applicable	Temperature indirectly affects health and aesthetics through impacts on disinfection, corrosion control and formation of biofilms in the distribution system.
O	Tetrachloroethylene (2015)	0.01		Spill or other point source of contamination	Health basis of MAC: Neurological effects (colour confusion) in humans Other: Classified as probably carcinogenic to humans, based on sufficient evidence in experimental animals and limited evidence in humans	Primarily a concern in groundwater, as it volatilizes easily from surface water; MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
O	Toluene (2014)	0.06	AO: 0.024	Emissions, effluents or spills from petroleum and chemical industries	Health basis of MAC: Adverse neurological effects, including vibration thresholds, colour discrimination, auditory thresholds, attention, memory and psychomotor functions Other: Insufficient information to determine whether toluene is carcinogenic to humans.	MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing. AO is based on odour.
A	Total dissolved solids (TDS) (1991)		AO: ≤ 500	Naturally occurring; sewage, urban and agricultural runoff, industrial wastewater	Not applicable	Based on taste; TDS above 500 mg/L results in excessive scaling in water pipes, water heaters, boilers and appliances; TDS is composed of calcium, magnesium, sodium, potassium, carbonate, bicarbonate, chloride, sulphate and nitrate.
O	Trichloroethylene (2005)	0.005		Industrial effluents and spills from improper disposal	Health basis of MAC: Developmental effects (heart malformations) Other: Classified as probable carcinogen	MAC takes into consideration all exposures from drinking water, which include ingestion, as well as

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
						inhalation and dermal absorption during showering and bathing.
O	2,4,6-Trichlorophenol (1987, 2005)	0.005	AO: ≤ 0.002	By-product of drinking water disinfection with chlorine; industrial effluents and spills	Health basis of MAC: Liver cancer (classified as probable carcinogen)	AO based on odour; levels above the AO would render drinking water unpalatable.
DBP	Trihalomethanes ³ (THMs) (2006)	0.1		By-product of drinking water disinfection with chlorine; industrial effluents	Health basis of MAC: Liver effects (fatty cysts) (chloroform classified as possible carcinogen) Other: Kidney and colorectal cancers	Refers to the total of chlorodibromomethane, chloroform, bromodichloromethane and bromoform; MAC based on health effects of chloroform. MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing. Utilities should make every effort to maintain concentrations as low as reasonably achievable without compromising the effectiveness of disinfection.

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
						Recommended strategy is precursor removal. The separate MAC for BDCM was rescinded in April 2009.
I	Uranium (2019)	0.02		Naturally occurring (erosion and weathering of rocks and soils); mill tailings; emissions from nuclear industry and combustion of coal and other fuels; phosphate fertilizers	Health basis of MAC: Kidney effects	Based on challenges and operational cost impacts for some private wells and small systems; MAC is for total uranium and is protective in relation to both chemical and radiological hazards.
O	Vinyl chloride (2013)	0.002 ALARA		Industrial effluents; degradation product from organic solvents in groundwater; leaching from polyvinyl chloride pipes	Health basis of MAC: Liver cancer (classified as human carcinogen) Other: Raynaud's disease, effects on bone, circulatory system, thyroid, spleen, central nervous system	Based on analytical achievability. MAC takes into consideration all exposures from drinking water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing. Leaching from polyvinyl chloride pipe is not expected to be significant.
O	Xylenes (total) (2014)	0.09	AO: 0.02	Emissions, effluents or spills from petroleum and chemical industries	Health basis of MAC: Adverse neuromuscular effects	MAC takes into consideration all exposures from drinking

Type ¹	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Applying the Guideline and Comments
					Other: Insufficient information to determine whether xylenes are carcinogenic to humans	water, which include ingestion, as well as inhalation and dermal absorption during showering and bathing. AO is based on odour.
I	Zinc (1979, 2005)		AO: ≤ 5.0	Naturally occurring; industrial and domestic emissions; leaching may occur from galvanized pipes, hot water tanks and brass fittings	Zinc is an essential element and is generally considered to be non-toxic, however levels above the AO in water would render it unpalatable.	AO based on taste; water with zinc levels above the AO tends to be opalescent and develops a greasy film when boiled; plumbing should be thoroughly flushed before water is consumed.

¹ Parameter types: **A** – Acceptability; **D** – Disinfectant; **DBP** – Disinfection by-product; **P** – Pesticide; **I** – Inorganic chemical; **O** – Organic chemical; **T** – Treatment related parameter.

In cases where total dichlorobenzenes are measured and concentrations exceed the most stringent value (0.005 mg/L), the concentrations of the individual isomers should be established.

³ Expressed as a locational running annual average of quarterly samples.

⁴ No units.

Table 3. Radiological Parameters

Guidelines for radiological parameters focus on routine operational conditions of existing and new water supplies and do not apply in the event of contamination during an emergency involving a large release of radionuclides into the environment. MACs have been established for the most commonly detected natural and artificial radionuclides in Canadian drinking water sources, using internationally accepted equations and principles and based solely on health considerations.

The MACs are based on exposure solely to a specific radionuclide. The radiological effects of two or more radionuclides in the same drinking water source are considered to be additive. Thus, the sum of the ratios of the observed concentration to the MAC for each contributing radionuclide should not exceed 1.

Water samples may be initially analysed for the presence of radioactivity using gross alpha and gross beta screening rather than measurements of individual radionuclides. If screening levels are exceeded (0.5 Bq/L for gross alpha and 1.0 Bq/L for gross beta), then concentrations of specific radionuclides should be analysed. A guideline for radon in drinking water is not deemed necessary and has not been established. Information on radon is presented because of its significance for indoor air quality in certain situations.

Parameter (published, reaffirmed)	MAC (Bq/L)	Common sources	Health basis of MAC	Comments
Cesium-137 (2009)	10	Nuclear weapons fallout and emissions from nuclear reactors	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	Fixation by sediments in aquatic environments reduces its concentration in water bodies. Ingested ¹³⁷ Cs is readily absorbed into soft tissues, but is eliminated relatively quickly.
Iodine-131 (2009)	6	Sewage effluent	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	No additional comments
Lead-210 (2009)	0.2	Naturally occurring (decay product of radon)	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	Corresponds to total lead concentration of 7×10^{-8} µg/L

Parameter (published, reaffirmed)	MAC (Bq/L)	Common sources	Health basis of MAC	Comments
Radium-226 (2009)	0.5	Naturally occurring	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	No additional comments
Radon (2009)	None required	Naturally occurring (leaching from radium-bearing rocks and soils; decay product of radium-226)	Health risk from ingestion considered negligible due to high volatility	Mainly a groundwater concern; if concentrations in drinking water exceed 2000 Bq/L actions should be taken to reduce release into indoor air (e.g. proper venting of drinking water supply)
Strontium-90 (2009)	5	Nuclear weapons fallout	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	Has a long residence time in bone and its beta particles have high energy. Radioactive strontium (90Sr) should not be confused with stable strontium. The two species of strontium have quite different origins, and their concentrations in drinking water are not correlated.
Tritium (2009)	7000	Naturally occurring (cosmogenic radiation); releases from nuclear reactors	Cancer of the lung, breast, thyroid, bone, digestive organs and skin; leukaemia	Not removed by drinking water treatment
Uranium 1999	N/A		MAC based on chemical properties	See information provided in Table 2

Table 4. Guidance Documents

In certain situations, Health Canada, in collaboration with the Federal-Provincial-Territorial Committee on Drinking Water, may choose to develop guidance documents for issues that do not meet the criteria for guideline development and for specific issues for which operational or management guidance is warranted. These documents are offered as information for drinking water authorities and help provide guidance relating to contaminants, drinking water management issues or emergency situations.

Parameter/subject (published)	Comments
Chloral hydrate in drinking water (2008)	Exposure levels in Canada far below concentration that would cause health effects; levels above 0.2 mg/L may indicate a concern for health effects and should be investigated.
Controlling corrosion in drinking water distribution systems (2009)	Addresses strategies to deal with leaching of lead from materials in the distribution system; sampling protocols can be used to assess corrosion and the effectiveness of remediation/control measures to reduce lead levels in drinking water; corrective measures are outlined to address lead sources.
Heterotrophic plate count (HPC) (2012)	A useful operational tool for monitoring general bacteriological water quality through the treatment process and in the distribution system. HPC results are not an indicator of water safety and should not be used as an indicator of potential adverse human health effects.
Issuing and rescinding boil water advisories in Canadian drinking water supplies (2015)	Summarizes factors for consideration when responsible authorities issue or rescind boil water advisories. Provides trend information on reasons boil water advisories are issued in Canada.
Issuing and rescinding drinking water avoidance advisories in emergency situations (2009)	Summarizes factors for consideration when responsible authorities issue or rescind drinking water avoidance advisories in emergency situations.
Natural organic matter in drinking water (NOM) (2020)	The presence and characteristics of natural organic matter (NOM) can have significant impacts on drinking water treatment processes, and consequently the safety of drinking water. Seasonal and weather-related events can significantly affect the concentration and character of NOM. This guidance document reviews and assesses: 1) the impacts of NOM and the associated indirect health risks; 2) source-specific treatability study requirements to ensure the most appropriate

Parameter/subject (published)	Comments
	process is selected to meet treated water quality goals; 3) treatment options and their effectiveness; 4) tools available to monitor raw, treated and distribution system water quality.
Overview of the Microbiological Aspects of Drinking Water Quality (2021)	Provides an overview of the microbiological considerations to ensure drinking water quality, integrating key content of the relevant guideline technical documents and guidance documents to illustrate how they fit into the source-to-tap approach.
Potassium from water softeners (2008)	Not a concern for general population; those with kidney disease or other conditions, such as heart disease, coronary artery disease, hypertension or diabetes, and those who are taking medications that interfere with normal body potassium handling should avoid the consumption of water treated by water softeners using potassium chloride.
Use of Enterococci as an indicator in Canadian drinking water supplies (2020)	Enterococci are a bacteriological indicator of fecal contamination. This indicator can supplement E. coli and total coliforms monitoring programs to provide additional information into fecal contamination issues. The document provides information on how enterococci can be used in a drinking water monitoring program.
Use of Quantitative Microbial Risk Assessment (QMRA) in Drinking Water (2019)	Provides guidance on the use of QMRA to assist in understanding microbiological risks in Canadian water systems.
Waterborne bacterial pathogens (2013)	Originate from human or animal feces or may be naturally occurring in the environment. Commonly associated with gastrointestinal upset (nausea, vomiting, diarrhoea); some pathogens may infect wounds, lungs, skin, eyes, central nervous system or liver. Document provides information on these pathogens and treatment options, and recommends using the source-to-tap approach to reduce their levels.

Table 5. Withdrawn Guidelines

Health Canada, in collaboration with the Federal-Provincial-Territorial Committee on Drinking Water, has established a science-based process to systematically review older guidelines and withdraw those that are no longer required. Guidelines are withdrawn for parameters that are no longer found in Canadian drinking water supplies at levels that could pose a risk to human health. This includes pesticides that are no longer registered for use in Canada and mixtures of contaminants that are addressed individually.

Type	Parameter	Type	Parameter
P	Aldicarb	P	Mirex
P	Aldrin + dieldrin	O	monochlorobenzene
P	Azinphos-methyl	P	paraquat
P	Bendiocarb	P	Parathion
P	Carbaryl	P	Pesticides (total)
P	Carbofuran	O	Phenols (total)
P	Chlordane (total isomers)	P	phorate
P	Cyanazine	O	Phthalic acid esters (PAE)
P	Diazinon	P	picloram
O	1,2-dichlorobenzene	O	Polychlorinated biphenyls (PCBs)
P	Dichlorodiphenyltrichloroethane (DDT) + metabolites	O	Polycyclic aromatic hydrocarbons (PAHs) (excluding benzo[a]pyrene)
O	2,4-dichlorophenol	O	Resin acids
P	Diclofop-methyl	P	Simazine
P	Dinoseb	O	Tannin
P	Diuron	P	Temephos
P	Endrin	P	Terbufos

Type	Parameter	Type	Parameter
O	Gasoline and its organic constituents	O	2,3,4,6-tetrachlorophenol
P	Heptachlor + heptachlor epoxide	O	Total organic carbon
O	Lignin	P	Toxaphene
P	Lindane	P	Triallate
P	Methoxychlor	P	2,4,5-Trichlorophenoxyacetic acid ² (2,4,5-T)
P	Methyl-parathion	P	2,4,5-Trichlorophenoxypropionic acid (2,4,5-TP)
P	Metolachlor	P	Trifluralin

Table 6. Guidelines and Guidance in Progress

The following are parameters for which Health Canada is developing or updating guidelines and guidance over the next few years.

- Acrylamide
- Antimony
- Arsenic
- Asbestos
- Atrazine
- Boron
- Bromoxynil
- Controlling corrosion in drinking water distribution systems
- 2,4-Dichlorophenoxy acetic acid
- Dimethoate/Omethoate
- Monitoring the biological stability of drinking water in distribution systems
- Haloacetic acids
- Iron
- Malathion
- Operational guidance for drinking water utilities
- Per- and polyfluoroalkyl substances (PFAS)
- Premise plumbing
- Trihalomethanes
- Turbidity
- Waterborne pathogens